



an EnerSys® company

Product Change Notification

PCN # 1141107

FlexPoint FPR1207-F Power Supply Product Discontinuation

1. Supplier Information Alpha Technologies, Ltd. 7700 Riverfront Gate, Burnaby, BC V5J 5M4 Canada Contact: Daljit Hothi Associate Product Manager 604.422.4490 daljit.hothi@enersys.com		2. Product Change Notification Number PCN # 1141107
3. Issue Date of Change November 07, 2014	4. System and Product Description The FlexPoint FPR1207-F has been discontinued and is replaced by FlexPoint FP1208-F.	
5. New Product ID FlexPoint FP1208-F : 010-353-20	6. Old Product ID FlexPoint FPR1207-F : 010-344-20	
7. Associated Products or Changes Affected FlexPoint FPR1207-F : 010-344-20		
8. Drawing No. N/A	9. Product Change Classification Class B Changes that are made to incorporate improvements in the design of existing products that result in better operation, improved testing and maintenance, longer life, service improvements, operation cost reductions to a customer, and/or addition of new features.	
10. Reason for Change FlexPoint FPR1207-F has been discontinued due to an unexpected component obsolescence in the global supply chain.		
11. Description of Change The FlexPoint FP1208-F is a drop-in replacement for the FlexPoint FPR1207-F. Noticeable differences are as follows:		
	FPR1207-F (010-344-20)	FP1208-F (010-353-20)
Dims(H" x W" x D")	7.75 x 8.75 x 3.0	6.6 x 7.5 x 3.28
Operating Temperature	32 to104°F (0 to 40°C)	4 to 113°F (-20 to 45°C)
Output	12Vdc, 7 Watts	12Vdc, 8 Watts
Battery(sold separately)	7.2Ah or 8Ah	5.1Ah or 7.2Ah or 8Ah



an EnerSys® company

Product Change Notification

12. Effect of Change Change will have no effect to system operation or usability what is stated in section 11.	
13. Material/Product Affected N/A	
14. Documentation Affected N/A	
15. Supplier Implementation Date Orders for FlexPoint FPR1207-F will not be accepted. Customers will be requested to revise PO's to FlexPoint FP1208-F.	16. Modification Completion Date N/A
17. Modification Location N/A	
18. Modification Cost N/A	
19. Location and Quantity of Equipment N/A	
20. Attachments N/A	
21. Comments None	