



## CXPS-MPS Mobile Power Grounding

Date: November 11<sup>th</sup>, 2019  
Model #: CXPS-MPS Mobile Power  
Part #: 0541124-XXX

### **Issue**

Due to the CXPS-MPS being mobile in nature, the unit may be installed incorrectly by not properly grounding the system. As there is a significant amount of potential power to be connected through the CXPS-MPS, all proper safety procedures must be followed.

With the use of a portable power system in different environments, from emergency backup to construction sites, the unit might come into contact with additional contaminant, compared to a permanently installed system.

### **Corrective Action**

Please refer to the [CXPS-MPS Quickstart](#) for the correct grounding locations and sizing. Please print off a permanent copy to be stored with the CXPS-MPS for future reference.

Every time the CXPS-MPS is used, ensure the unit is clean of all foreign contaminants (ie: dirt, plastic, metal shavings).

For additional assistance or if you have any questions regarding this notification, please contact Alpha Technical Support at 1-888-462-7487 or [www.alpha.ca/report-a-problem](http://www.alpha.ca/report-a-problem).

Sincerely,

JD Fraser  
Associate Product Manager  
Alpha Technologies Ltd.  
[jd.fraser@alpha.ca](mailto:jd.fraser@alpha.ca)