



an EnerSys company

## PCN # [0470474-PCN] CXPS-W Plug in Breaker Adaptor Kits

<b>1. Supplier Information</b> Alpha Technologies, Ltd. 7700 Riverfront Gate Burnaby, BC V5J 5M4 Canada	<b>1.6 Supplier Contact Info</b> Contact: JD Fraser Product Manager 1.604.415.7493 <a href="mailto:jd.fraser@alpha.ca">jd.fraser@alpha.ca</a>												
<b>2. Product Change Notification Number</b> PCN # 0470474-PCN	<b>3. Issue Date of Change</b> February 18, 2021												
<b>4. System Affected</b> Major System Affected: CXPS-W Subsystem Affected: 2 Pole and 3 Pole Adaptors Hardware Affected: Y Firmware Affected: N Software Affected: N													
<b>5. New Product ID</b> <table border="1" data-bbox="230 1194 773 1312"> <thead> <tr> <th>Model</th> <th>Part Number</th> </tr> </thead> <tbody> <tr> <td>Rev C</td> <td>0370316-001</td> </tr> <tr> <td>Rev D</td> <td>0370317-001</td> </tr> </tbody> </table>	Model	Part Number	Rev C	0370316-001	Rev D	0370317-001	<b>6. Old Product ID</b> <table border="1" data-bbox="850 1194 1382 1312"> <thead> <tr> <th>Model</th> <th>Part Number</th> </tr> </thead> <tbody> <tr> <td>Rev B</td> <td>0370316-001</td> </tr> <tr> <td>Rev C</td> <td>0370317-001</td> </tr> </tbody> </table>	Model	Part Number	Rev B	0370316-001	Rev C	0370317-001
Model	Part Number												
Rev C	0370316-001												
Rev D	0370317-001												
Model	Part Number												
Rev B	0370316-001												
Rev C	0370317-001												
<b>7. New CLEI Code</b> N/A	<b>8. Old CLEI Code</b> N/A												
<b>9. Associated Products or Changes Affected</b> PN: 0541133-001 PN: 0540551-001 PN: 0541133-001													
<b>10. Drawing Number</b> 5903941-00, 5903940-00													
<b>11. Classification of Change</b> D	<b>12. Reason for Classification</b> Components in the kit are discontinued.												



an EnerSys company

<b>13. Reason for Change</b> The market demand for landing smaller ¼" by 5/8" center lugs on two pole and three pole adaptor kits has disappeared with customers using 3/8" by 1" center lugs for amperages above 125A.	
<b>14.1 Description of Change</b> Removed PN: 5903940-001 from 0370316-001 Removed PN: 5903941-001 from 0370317-001	
<b>14.2 Change Verification Procedures</b> Visually inspect that the kits only contain two busbar adaptors not three.	
<b>15. Safety Notification</b> N/A	
<b>16. Material Affected</b> N/A	
<b>17. Documentation Affected</b> N/A	
<b>18. Supplier Implementation Date</b> February 18, 2021	<b>19. Modification Completion Date</b> February 18, 2021
<b>20. Modification Location</b> Burnaby, BC	
<b>21. Modification Cost</b> N/A	
<b>22. Location and Quantity of Equipment</b> N/A	
<b>23. Attachments</b> N/A	
<b>24. Comments</b> Adaptor bars; 5903940-001 and 5903941-001 will be available for individual purchase.	

- End of Product Change Notification -