



Alpha Technologies Software Update Notification: Micro and SNMP Card Version 2.00.04

Date: February 8, 2017

Model #: FXM 350, 650, 1100, 2000 & Micro 100, 350, 1000

Release: 2.00.04

Alpha Technologies is pleased to announce the release of 2.00.04 firmware release (for the Alpha FXM 350, 650, 1100, 2000 & Alpha Micro 100, 350, 1000 - uninterruptible power supplies).

New Features and Improvements:

Micro Card Firmware Version 2.00.04

- Improved battery runtime remaining algorithm
- Improved accuracy in battery temperature measurement
- Improved immunity against false DC overload alarm detection
- Added power outage as an alarm with user configurable time delay
- Added "output relay" configuration to open an external relay based on output voltage range
- Standard constant as a default charging method from the factory
- Fixed open issues:
 - Auto-battery test does not work if set to midnight
 - Overload fault remains too short for an email to be sent
 - UPS mode status is not refreshed on "Remain Tm" parameter screen on LCD
 - Can't change date and time using the RS232 connection when the date entered is the 31st day of the month
 - RS232 command "c#=X" fails if 'X'=15

SNMP Card Firmware Version 2.00.04

- Added ability to save event log to csv file from the webpage
- Added email authentication in clear text for SMTP server
- Added a time zone setting to time and date webpage
- Added open for discovery unsolicited ARP to detect unit's SNMP card by the networking switch
- Added power outage alarm webpages
- Access to network configuration section requires login
- Display IP address if DHCP is enabled on the webpage and FXM LCD
- Corrected upsSecondsOnBattery MIB definition to UPSMinutesOnBattery
- Fixed open issues:
 - Energy counter reached 2048kWh and is not measuring consumption any further
 - Incorrect time stamps on FXM event notifications



Your Power Solutions Partner

- Implemented automatic status update for FXM350
- Fixed refresh feature on unit configuration page
- Fixed issue where alarm is in the table view, but not under SNMP UpsAlarmsPresent alarm count

All software updates for Alpha products can be found online:

<http://www.alpha.ca/software-firmware-downloads>

For additional assistance or if you have any questions regarding this notification, please contact Alpha Technical Support at 1-888-462-7487 or www.alpha.ca/report-a-problem.

Daljit Hothi

Associate Product Manager, AC Solutions

Alpha Technologies Ltd.

daljit.hothi@alpha.ca

For assistance, contact Alpha Technical Support:

Toll Free North America: 1-888-462-7487

International: +1-604-436-5547

Monday - Friday, 7:00 AM - 5:00 PM PST for regular inquires

24/7 for emergency support

[Click here to report a problem](#)