



an EnerSys company

## PCN # [0470448-PCN] Ciena Custom PowerWorx Panels

| <b>1. Supplier Information</b><br>Alpha Technologies, Ltd.<br>7700 Riverfront Gate, Burnaby, BC<br>V5J 5M4 Canada  | <b>1.6 Supplier Contact Info</b><br>Contact: Gary Thrift<br>Product Manager<br>604-318-5317<br>gary.thrift@alpha.ca |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
|--|---|--|-------|-------------------|-----|-----|--|----------|--|-------|-------------------|---------------------|--------------|---------------------|--------------|---------------------|--------------|---------------------|--------------|
| <b>2. Product Change Notification Number</b><br>PCN # 0470448-PCN  | <b>3. Issue Date of Change</b><br>3/10/2020   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| <b>4. System Affected</b><br>Major System Affected: PWXCNA<br>Subsystem Affected: PowerWorx Ciena Panels<br>Hardware Affected: Y<br>Firmware Affected: N<br>Software Affected: N   |   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| <b>5. New Product ID</b><br><br><table border="1" data-bbox="191 1150 769 1266"> <thead> <tr> <th colspan="2">Hardware</th> </tr> <tr> <th>Model</th> <th>Part Number (P/N)</th> </tr> </thead> <tbody> <tr> <td>N/A</td> <td>N/A</td> </tr> </tbody> </table> | Hardware  |  | Model | Part Number (P/N) | N/A | N/A | <b>6. Old Product ID</b><br><br><table border="1" data-bbox="802 1150 1383 1354"> <thead> <tr> <th colspan="2">Hardware</th> </tr> <tr> <th>Model</th> <th>Part Number (P/N)</th> </tr> </thead> <tbody> <tr> <td>PWX-071FC440YDPWN-C</td> <td>300001734729</td> </tr> <tr> <td>PWX-071FC420YDPWN-C</td> <td>300001734730</td> </tr> <tr> <td>PWX-071FC410YDPWN-C</td> <td>300001736276</td> </tr> <tr> <td>PWX-071FC450YDPWN-C</td> <td>300001736277</td> </tr> </tbody> </table> | Hardware |  | Model | Part Number (P/N) | PWX-071FC440YDPWN-C | 300001734729 | PWX-071FC420YDPWN-C | 300001734730 | PWX-071FC410YDPWN-C | 300001736276 | PWX-071FC450YDPWN-C | 300001736277 |
| Hardware   |   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| Model  | Part Number (P/N)   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| N/A  | N/A   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| Hardware   |   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| Model  | Part Number (P/N)   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| PWX-071FC440YDPWN-C  | 300001734729  |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| PWX-071FC420YDPWN-C  | 300001734730  |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| PWX-071FC410YDPWN-C  | 300001736276  |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| PWX-071FC450YDPWN-C  | 300001736277  |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| <b>7. New CLEI Code</b><br>N/A   | <b>8. Old CLEI Code</b><br>WMPYABDGRB<br>WMPYABUGRA<br>WOMYABPFRA<br>WOMYABRFRA                                     |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| <b>9. Associated Products or Changes Affected</b><br>N/A   |   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |
| <b>10. Drawing Number</b><br>300001726163  |   |  |       |                   |     |     |  |          |  |       |                   |                     |              |                     |              |                     |              |                     |              |



an EnerSys company

|   |  |
|---|--|
| <b>11. Classification of Change</b><br>D  | <b>12. Reason for Classification</b><br>This change incorporates minor design improvements |
| <b>13. Reason for Change</b><br>Field failures of proper connection from connecting bus bar due to alignment issues |  |
| <b>14.1 Description of Change</b><br>Modified holes from .201 to .201 x .320 slots                                  |  |
| <b>14.2 Change Verification Procedures</b><br>N/A   |  |
| <b>15. Safety Notification</b><br>N/A   |  |
| <b>16. Material Affected</b><br>300001726164  |  |
| <b>17. Documentation Affected</b><br>N/A  |  |
| <b>18. Supplier Implementation Date</b><br>N/A  | <b>19. Modification Completion Date</b><br>N/A   |
| <b>20. Modification Location</b><br>N/A   |  |
| <b>21. Modification Cost</b><br>N/A   |  |
| <b>22. Location and Quantity of Equipment</b><br>N/A  |  |
| <b>23. Attachments</b><br>N/A   |  |
| <b>24. Comments</b><br>N/A  |  |